

Lighting for ATCTs			
Space	Level (fc)	Type	Notes
Lobby	10-20	Fluorescent	
Elevator	10-20	Fluorescent	
Elevator Machine Room	10-20	Fluorescent	
Mechanical and Electrical Room	40-60	Fluorescent	
Simulator Classroom	30-50	Fluorescent	Dimmable
Administration	40-60	Fluorescent	
Chief Controller's Office	40-60	Fluorescent	
Training Room	20-40	Fluorescent	
Lower Equipment Room	40-60	Fluorescent	
Upper Equipment Room	40-60	Fluorescent	
Ready/Break Room	30-50	Fluorescent	
Mechanical Room	40-60	Fluorescent	
Cab	40-60	Incandescent and Spotlight	Dimmable. Provide task lighting at 60-120 fc at work locations
Toilet Room	40-50	Fluorescent	
Communications/Power Closet	40-60	Fluorescent	
Stairs	10-20	Fluorescent	

- Provide emergency battery ballast fixtures in stairs and in each room.

Note: The following table is to be used as a tool to be filled out when developing the Project Definition Customer Concept Design (CCD) and to be utilized at the ATCT design charrette.