

Lighting for RAPCONs			
Space	Level (fc)	Type	Notes
Admin-Chief Controller	40-60	Fluorescent	
Admin-CATCT-CSE (Chief, Air Traffic Control Training, Chief, Standardization and Evaluation)	40-60	Fluorescent	
Admin-CBI (Computer-based Instruction)	40-60	Fluorescent	
Admin-Administrative Area	40-60	Fluorescent	
Male Restroom	40-50	Fluorescent	
Locker	40-50	Fluorescent	
Shower	40-50	Fluorescent	
Female Restroom	40-50	Fluorescent	
Locker	40-50	Fluorescent	
Shower	40-50	Fluorescent	
Mechanical	40-60	Fluorescent	
Electrical	40-60	Fluorescent	
Telephone Room	40-60	Fluorescent	
TERPS/DSS (Terminal Procedures/ Data Systems Specialist)	40-60	Fluorescent	
Ops/IFR Room	0-50	Fluorescent	Dimmable
Simulator Room	0-50	Fluorescent	Dimmable
Briefing/Conference Room	0-50	Fluorescent	Dimmable
Vestibule	10-20	Fluorescent	
Equipment Room	40-60	Fluorescent	
Storage Room	40-60	Fluorescent	
Maintenance Room	40-60	Fluorescent	Provide task lighting at workbench
Break Room	30-50	Fluorescent	
Corridors	10-20	Fluorescent	
Janitor	10-20	Fluorescent	
Exterior Area	0.5	HPS	
Exterior Service Area	0.5	HPS	
Exterior Parking Area	0.5	HPS	

Note: The following table is to be used as a tool to be filled out when developing the Project Definition Customer Concept Design (CCD) and to be utilized at the RAPCON design charrette.